



DECTEC "STRIP-IN" DETAIL, W/ RAINSCREEN

NOTES:

1. INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH MANUFACTURERS SPECIFICATIONS.
2. DO NOT SCALE DRAWINGS.
3. DECTEC MEMBRANE FLASHING TO BE MINIMUM OF 15" WIDE.
4. MIN. SLOPE 1/4":12" AWAY FROM STRUCTURE.
5. DECTEC MEMBRANE/FLASHING TO BE FULLY ADHERED ON ALL VERTICAL FLASHINGS WITH SBA100.
6. PLYWOOD SUBSTRATES TO BE EXTERIOR GRADE MIN. 5/8" T&G OR ALTERNATIVELY MIN. 5/8" WITH ALL PLYWOOD JOINT BLOCKED FROM BELOW.
7. AS A SUPPLIER OF MATERIALS ONLY, SKYLINE BUILDING SYSTEMS INC. DOES NOT ASSUME RESPONSIBILITY FOR ERRORS IN DESIGN, ENGINEERING, QUANTITIES, OR DIMENSIONS. THE ARCHITECT, CONTRACTORS, OR OWNERS REPRESENTATIVE MUST VERIFY ALL DIMENSIONS, SIZES AND SUITABILITY OF DETAILS.